

**SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 1:55 PM

**Daily Diary Report by Bid Item**

Contract No.: 04-0120F4

Diary #: 451 Const Calendar Day: 769 Date: 17-Oct-2011 Monday

Inspector Name: Wilcox, Jason Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 06:30 am 05:00 pm Break: 00:30 Over Time: 02:00

Federal ID:

Location:

Reviewer: Jefferson, Paul

Approved Date:

Status: Submit

**04-0120F4  
04-SF-80-13.2/13.9  
Self-Anchored  
Suspension Bridge****Weather****Temperature** 7 AM 50 - 60 12 PM 60 - 70 4PM 60 - 70**Precipitation** **Condition** ClearWorking Day ☒ If no, explain:**Diary:**

Dispute

**General Comments**

Clear and mild

- 0800 hrs SAS staff meeting
- Reviewed RFI 2601, RFI 2602, and RFI 2565.
- Reviewed Special Provisions
- Reviewed Submittal 1265R02 – CB19 Jacking Plan
- Discuss Submittal 2379R00 and 2379R01 with Thanh Le and Tai-Lin Liu. Step 94 in Sub 2379R00 incorrectly states that Step 1E shall be complete prior to connecting splice 12/13. This does not make sense since the connection cannot be made before it is connected. Similar listing occur at stage 97 (E line) and 100 (W line). Tai-Lin and I spoke with Kevin Smith from ABF and he confirmed that those cells in the spreadsheet should have been left blank.
- Reviewed buyoff sheets for the Punchlist with Dan Hester from ABF. We are to meet tomorrow morning to finalize the prepared sheets.
- Diary work.
- Site visit to observe progress of field operations.

Accrued 2 hours of overtime covering the contractor's hours.

**04-0120F4 Bid Item: 056 E-L13-ALB.056 E Line Lift13 Align & Bolt**

AMERICAN BRIDGE/FLUOR, A JV

**04-0120F4 Bid Item: 056 E-L13-WEL.056 E Line Lift13 Weld**

AMERICAN BRIDGE/FLUOR, A JV

**04-0120F4 Bid Item: 056 W-L13-ALB.056 W Line Lift13 Align & Bolt**

AMERICAN BRIDGE/FLUOR, A JV



---

### ***Daily Diary Report by Bid Item***

**Job Name:** 04-0120F4    **Inspector Name** Wilcox, Jason    **Diary #:** 451    **Date:** 17-Oct-2011    **Monday**

---

<b>04-0120F4</b>	<b>Bid Item:</b> 056	<b>W-L13-WEL.056</b>	<b>W Line Lift13 Weld</b>
AMERICAN BRIDGE/FLUOR, A JV			

<b>04-0120F4</b>	<b>Bid Item:</b> 056	<b>X-L13-CBM.056</b>	<b>E-W Line Cross Over Lift13 Cross Beam</b>
AMERICAN BRIDGE/FLUOR, A JV			